

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES 1 3
2. AMENDMENT/MODIFICATION NUMBER 00002	3. EFFECTIVE DATE 02/17/2017	4. REQUISITION/PURCHASE REQUISITION NUMBER	5. PROJECT NUMBER (If applicable) 4668187	
6. ISSUED BY USCG CEU Cleveland(cp) 1240 East Ninth Street, Room 2179 Cleveland, OH 44199-2060	CODE	7. ADMINISTERED BY (If other than Item 6) Same as block #6	CODE	
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code) D5 RMACC Contractors			<input checked="" type="checkbox"/> 9A. AMENDMENT OF SOLICITATION NUMBER HSCG83-17-R-PCR056	<input checked="" type="checkbox"/> 9B. DATED (SEE ITEM 11) 20 JAN 2017
			<input type="checkbox"/> 10A. MODIFICATION OF CONTRACT/ORDER NUMBER	<input type="checkbox"/> 10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended. is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE <input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

- The purpose of this amendment is to address questions submitted by D5 RMACC Contractors.
- The proposal due date is extended to 2 March 2017; 2:30 EST.
- Sign blocks 15a & 15b to acknowledge receipt of Amendments and return with proposal.
- All other terms and conditions remain the same.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Patricia J. Korenchen	
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA Patricia J. Korenchen (Signature of Contracting Officer)	16C. DATE SIGNED 2/17/17

Previous edition unusable

HSCG83-17-R-PCR056
REPAIR HVAC AT USCG STA LITTLE CREEK
CONTINUATION PAGE 2 OF 3

Q1: Reference Amendment 00001. Will you please provide us with an architectural sheet to scale with the existing ceiling plan for bid purposes?

A1: Provided (see attachment on email) is the most recent as-built reflected ceiling plan. It is approximately 20 years old.

Q2: There does not appear to be any GPM values for the FCU, but the details indicate they have auto flow valves for water. We assume each has a cold and hot water valve. Can you confirm? Can you also confirm the valves will be auto flows and not manual circuit setters?

A2: Yes, the units have hot and cold water valves and auto flow valves.

Q3: Can you confirm that you do want the PreTAB readings included in the price quote.

A3: Work required is identified in the specification and drawings. PreTAB readings are not required.

Q4: Can we have the model and make of the existing Fan Coil Units?

A4: Make/model information for existing fan coil units is not available.

Q5: Does the entire slab under the existing AHU need to be replaced including that under the hot water heaters?

A5: The concrete slab under the existing AHU can be modified as necessary to fit the dimensions of newly installed equipment if it is larger and does not need to be modified for smaller equipment. Added concrete shall be doweled to existing concrete and anchored to the floor. This work will not disturb the water heaters.

Q6: To what extent is the plywood flooring under the AHU need to be replaced? Extent of damage is a matter of perspective/expectations.

A6: The flooring replacement is not expected to exceed 100 sq ft. For bidding purposes, 100 sq ft of subfloor will be removed and replaced. This work will not disturb the water heaters.

Q7: Does the existing drywall in the boiler room have to be completely removed prior to installing the insulation and new drywall?

A7: Drywall remaining in the boiler room only needs to be removed to the extent that is required to provide a clean and even finish with the remaining drywall.

HSCG83-17-R-PCR056
REPAIR HVAC AT USCG STA LITTLE CREEK
CONTINUATION PAGE 3 OF 3

Q8: Can we use 3" equipment mounting pads in lieu of concrete for leveling and lighter weight on the second floor. It is made for this application.

A8: No, see response to #5.